

MANUAL

Terra DC wallbox Installation Manual



Notice

This document contains information about one or more ABB products and may include a description of or a reference to one or more standards that may be generally relevant to the ABB products. The presence of any such description of a standard or reference to a standard is not a representation that all of the ABB products referenced in this document support all of the features of the described or referenced standard. In order to determine the specific features supported by a particular ABB product, the reader should consult the product specifications for the particular ABB product.

ABB may have one or more patents or pending patent applications protecting the intellectual property in the ABB products described in this document.

The information in this document is subject to change without notice and should not be construed as a commitment by ABB. ABB assumes no responsibility for any errors that may appear in this document

In no event shall ABB be liable for direct, indirect, special, incidental or consequential damages of any nature or kind arising from the use of this document, nor shall ABB be liable for incidental or consequential damages arising from use of any software or hardware described in this document.

This document and parts thereof must not be reproduced or copied without written permission from ABB, and the contents thereof must not be imparted to a third party nor used for any unauthorized purpose.

Copyrights

All rights to copyrights, registered trademarks, and trademarks reside with their respective owners.

Copyright © 2018 ABB.

All rights reserved.



Contents

1	Intro	duction	6		
	1.1	Preface	6		
	1.2	Intended document users			
	1.3	Similarities and differences between Terra DC Wallbox EU and NAM	6		
	1.4	Terra DC Wallbox version description	7		
	1.5	Signs			
		1.5.1 Owner responsibilities	8		
		1.5.2 Tilting and handling	<u>c</u>		
		1.5.3 Sharp edges	<u>S</u>		
		1.5.4 Electric hazards	<u>c</u>		
		1.5.5 Installation safety	9		
	1.6	1.6 Environment and disposal of waste	10		
2	Desc	ription of the product			
	2.1	Overview of the system			
		2.1.1 Complete overview			
		2.1.2 Outside view			
		2.1.3 Inside view			
	2.2	Geometry of infrastructure			
		2.2.1 Required space for placing and maintaining the Terra DC Wallbox			
		2.2.2 Ventilation and airflow of the Terra DC Wallbox			
	2.3	Electrical engineering			
		2.3.1 Requirements External RCD/GFCI			
		2.3.2 Conductor and cable diameter	15		
3	Site	Site design			
	3.1	Cable reach			
	3.2	Different alignment possibilities			
4	Site construction				
	4.1	About construction			
	4.2	Power feed			
	4.3	Instruction for a wall bearing			
	4.4	Power cable			
	4.5	Internet connection	19		
5	Rece	iving, Placing and connecting	20		
	5.1	Receiving the Wallbox			
	5.2	Unpacking Wallox, mounting preparations			
		5.2.1 Unpacking			
		5.2.2 Mounting preparations			
	5.3	Move cabinet to position			
		5.3.1 Options			
	5.4	Mounting the Terra DC Wallbox			
		5.4.1 Mounting the Terra DC Wallbox	23		



		5.4.2	Install cable gland(s)	26
	5.5	Connec	t cables	28
		5.5.1	Connect PE of power cable	28
		5.5.2	Connect power cable	29
		5.5.3	Connect network cable	30
6	Com	mission	ing	31
	6.1		ssioning preparation	
7	Cleaning of the cabinet			33
	7.1	Cleanir	ng of the cabinet	33
8	Tech	nical Da	ta	34
	8.1	Electric	cal data	34
	8.2	Mechai	nical data	36
	8.3	Enviror	nment	36
	8.4	Certific	cations	36
9	Cont	act info	rmation	37
10	Appe	endix A -	Mounting points	38
			C Wallbox Charger wall mounting	
11	Appe	endix B -	Disposal instruction	39
			ve on Waste Flectrical and Flectronic Equipment (WFFF = 2012/19/FU)	



Glossary

AC

Alternating Current.

CCS

Combined Charging System. This is the name of the charging protocol of European and North-American car makers.

CHAdeMO

DC fast charging method for electric vehicles.

Contractor

Entity hired by the owner / site operator to do engineering, civil and electrical installation work.

DC

Direct Current.

ΕV

Electric Vehicle.

Grid provider

Company responsible for the transportation and distribution of electricity.

нмі

Human Machine Interface; the display/screen on the charger.

NOC

ABB Network Operating Centre; remotely checks the correct functioning of the charger.

Owner

The legal owner of the charger.

OCPP

Open Charge Point Protocol. Open standard for communication with charge stations.

PΕ

Protective Earth.

PPE

Personal Protective Equipment. Equipment such as safety shoes, helmet, glasses, gloves.

RCD

Residual Current Device. Breaks the connection if a residual current is detected.

RFID

Radio-Frequency IDentification. RFID is acommunication technology by means of radio waves to transfer data over a very short distance between a reader and an electronic tag or card.

Site operator

This entity is responsible for the day to day control of the charger. The site operator can be the owner, but not necessarily.

User

The owner of an electric vehicle, who uses the Charge Station to charge that vehicle.





1 Introduction

1.1 Preface

This guide describes and highlights the physical installation of the Terra DC Wallbox at its location.

The Terra DC Wallbox Charging Stations are easy to install DC fast chargers for electric vehicles. Fast chargers are electrical installations with high electric currents. Therefore, the installation must be planned carefully, and must be done by certified personnel only (according to local standards). Local regulations shall take precedence if they list different installation requirements than prescribed in this Installation Manual.

The Terra DC Wallbox European and North American version is physically the same charger. The main difference is the input power they can be supplied by (three-phase for Europe, single phase or three phase for North Americas). The differences Terra DC Wallbox EU and NAM, and the consequences for the installation are described in a separate section 1.3.

As the physical installation of both types is equal, they will be referred to hereafter as Terra DC Wallbox only and this will account for both types, unless specifically stated otherwise.

Both types come in different versions, depending on the outlet types. The different versions are described in a separate paragraph.

Before installing the DC Wallbox, read this installation guide carefully and attentively. Follow the instructions in this Installation Guide. ABB is not responsible for any damage that has been caused by not or incorrectly following and executing the instruction described in this manual.

1.2 Intended document users

This document is intended to be used by:

- Customers who purchased a Terra DC Wallbox, or are in the process of ordering and want to know in more detail how it has to be installed.
- Contractors who are responsible for site preparation and/or installation of a Terra DC Wallbox (EU or NAM).

1.3 Similarities and differences between Terra DC Wallbox EU and NAM

The Terra DC Wallbox EU and NAM chargers are identical in their outer appearance and physical dimensions. The physical installation of the Terra DC Wallbox EU and NAM can thus be handled in a very similar way.

2019-10-22 6/40

On the inside of the system there are some differences. The Terra DC Wallbox EU version has a AC input board provided with contact blocks for main connection that are designed to be connected with a three phase + neutral power grid. On the other hand, the NAM version has a different AC input board designed to be connected with a phase to phase power grid.

1.4 Terra DC Wallbox version description

The Terra DC Wallbox is available in different versions depending on the available outlets.

The versions are:

Version	CCS2	CCS 1	CHAdeMO EU	CHAdeMO UL
Terra DC Wallbox C EU	Χ			
Terra DC Wallbox J EU			X	
Terra DC Wallbox CJ EU	Χ		X	
Terra DC Wallbox C UL		X		
Terra DC Wallbox J UL				X
Terra DC Wallbox CJ UL		Х		Х

- C CCS (Combo) standard
- J CHAdeMO standard

1.5 Signs

The following signs are used on the equipment and in this manual:



DANGER Hazardous voltage

Identifies a hazard that could result in severe injury or death through electrocution.



WARNING

Various

Identifies a hazard that could result in severe injury or death.



WARNING Rotating parts

Identifies a hazard that could result in injury due to the presence of rotating or moving parts.

22-OCT-19 7/40



WARNING Pinch Hazard

Identifies a hazard that could result in injuries, in which some body parts are pinched or crushed.



CAUTION Various

Identifies a hazard that could result in damage to the machine, other equipment, and/or environmental pollution.



CAUTION Environmental damage

Identifies a hazard that could result in environmental damage and/or environmental pollution.



NOTICE

Contains remarks, suggestions or advice.

1.5.1 Owner responsibilities

The owner and site operator are required:

- To operate the charge station with the protective devices installed and to make sure all protective devices are correctly installed after carrying out installation or maintenance.
- To write an emergency plan that instructs people what to do in case of emergency.
- To prepare the site where the wall box charge station will be installed, according to the requirements described in this guide.
- To make sure that there is enough space around the charger to carry out maintenance work.
- To appoint a person responsible for the safe operation of the charge station and for the coordination of all work.
- The owner is cautioned that changes or modifications not expressly approved by ABB could void the owner's authority to operate the equipment and ABB's warranty policy
- Neither ABB nor its affiliates shall be liable to the purchaser of this product or third parties for damages, losses, costs or expenses incurred by purchaser or third parties as a result of: an accident, misuse or abuse of this product or unauthorized modifications, repairs or alterations to this product, or failure to strictly comply ABB operating and maintenance instructions.

22-OCT-19 8/40

1.5.2 Tilting and handling



WARNING

Heavy equipment

The Terra DC Wallbox weighs about 70 kg. Handling Instructions:

- 1. Consider always two people to install and hang a Terra DC Wallbox to a wall.
- 2. Do not drop the Terra DC Wallbox.

1.5.3 Sharp edges



WARNING

Sharp metal edges

There could be sharp metal edges inside the Terra DC Wallbox. It is recommended to wear mash protecting gloves when working inside the charger.

1.5.4 Electric hazards



DANGER

Hazardous voltage

The Terra DC Wallbox contains conductors under hazardous electrical voltages. The grid terminals on the internal DIN rail may carry hazardous voltages, even if all circuit breakers are switched off.

1.5.5 Installation safety



DANGER

Hazardous voltage

Instructions:

- 1. Always switch off the external group switch upstream (Main breaker, RCD and disconnector or) before performing any installation, disassembly, repair or replacement of components.
- 2. Do a voltage check and make sure that the electrical power is disconnected from the system.
- 3. Only ABB certified technicians are permitted to commission the Terra DC Wallbox.
- 4. When the system is in an open or dangerous condition, do not allow unqualified persons to go near it. Instruct and warn people about the potential harmful high voltages.
- 5. The installation and maintenance personnel must supply their own lighting equipment, since the Terra DC Wallbox has no lights inside the cabinet.
- 6. Always connect the Protective Earth (PE) first, before connecting the neutral (N) and Phase (P) wiring.
- 7. Correctly fixate the enclosure of the Terra DC Wallbox after installation or service operations.

22-OCT-19 9/40

1.6 1.6 Environment and disposal of waste




NOTICE

Always observe the local rules and regulations with respect to processing (non-reusable) parts of the Terra DC Wallbox.

2 Description of the product

2.1 Overview of the system

2.1.1 Complete overview




Example of a complete installation

- A Power distribution board of the owner
- B Cables in cable conduit (if required)
- C Terra DC Wallbox
- D Parking space for charging
- E Electric vehicle

22-OCT-19 10/40

2.1.2 Outside view



A Display / HMI

B RFID card reader

C Charging outlets DC

D Air outlet

E Emergency button


F AC input cable

G Air inlet

H Gunholder (optional)

22-OCT-19 11/40

2.1.3 Inside view



A AC input board
B CPI and IMI boards
C External Fan (2x)

D Cable gland for DC output(2x) E Cable gland for AC input


2.2 Geometry of infrastructure

2.2.1 Required space for placing and maintaining the Terra DC Wallbox

The Terra DC Wallbox requires a minimum space of 900 x 1200 mm. This space is calculated as follows:

- Size Charger W x D x H: 304.5 x 512 x 770 mm.
- Bottom side 600 mm (400 mm from the Terra DC Wallbox in order to avoid obstacles for the electrical connection).
- Left and right side 300 mm, in order to operate without obstacles on the lateral side of the Terra DC Wallbox.

22-OCT-19 12/40



2.2.2 Ventilation and airflow of the Terra DC Wallbox


The Terra DC Wallbox has an air inlet on the bottom side and outlet on the top side.



NOTICE

Free air flow

If necessary, take precautions to prevent snow or objects from blocking the in- and outlets.



22-OCT-19 13/40

2.3 Electrical engineering

The electrical installation must be completed according to the local safety and electrical regulations and laws.

In general, the installer should follow the following prescriptions for the electrical installation of the devices upstream the installation.

IEC prescription:

- Installation of charging stations must be according to IEC 60364-7-722 and/or any applicable national rules
- Each charging station must be individually protected via a separate upstream RCD (Residual Current Device) at least of type A with a rated residual operating current not exceeding 30 mA.
- As all variant have an internal a DC fault current monitoring function, a DC fault current over 6 mA does NOT occur on the AC-input side of the TERRA DC WALLBOX, and thus an upstream RCD of type B is not required, nevertheless local regulation could require a RCD of Type B independent of internal DC fault current limitation NOTE. According to the standard for RCDs, type A RCDs are able to tolerate 6 mA of DC fault current while still maintaining their correct functionality.
- Fuses or equivalent circuit breaker rated to respect the charger specifications must be used (ref. cfr 16.1, IEC 61851-1:2017)

North American prescriptions:

- Each charging station must be connected via a separate GFCI (Ground Fault Circuit Interrupter /or equivalent RCD device) for the personal protection from the hazard of electric shock. The protection must be proven to withstand the presence of DC currents >6mA not blinding the leakage detection (type B RCD or equivalent leakage detection)
- Fuses or equivalent circuit breaker rated to respect the charger specifications must be used

2.3.1 Requirements External RCD/GFCI



NOTICE

External RCD/GFCI not included in delivery scope

Upstream RCD/GFCI's are explicitly excluded from ABB's delivery scope and belong to the scope of the installation company. The locally certified installation company can base the RCD/GFCI device type, amongst other external factors, on below charger characteristics.

DC-charging side requires immunity for short current peaks over PE

When the charger engages the DC charging (at the beginning of every charger session in the pre-charge phase) a relay switches and turns on the input to the power modules. A synchronic engagement of the phases in the relay in combination with the electrical capacity in the input power part, can cause incidental very short (25 microseconds) current peaks of up to 60A over the Protective Earth. The amplitude of the Ampere peaks can vary with the location and is dependent on grid and earth impedance. Given the switching characteristics of the DC section of the charger we give you the advice to select an

22-OCT-19 14/40

RCD/GFCI that has proven to be able to withstand these short current peaks (high immunity).



CAUTION

Responsibility to comply with local regulations

The installation company is responsibly to design and install the electrical installation according the local regulations.

2.3.2 Conductor and cable diameter

The diameter of the electrical conductor of the ground cables depends on the length, method of installation, etc. This must be determined by your contractor.

The maximum cross section is 35 mm².

The maximum diameter of the (grid) cable entering the cabinet is 32 mm. The minimum diameter with the standard fitted cable gland insert is 22 mm.

22-OCT-19 15/40


3 Site design

A site for EV charging can be designed in many different setups. This section is intended to give some useful information on the placement of a charger with respect to parking spaces and the vehicle inlets for the charging cable.

3.1 Cable reach

The charging cables of the Terra DC Wallbox charger can reach from 3.5 to 7 meters long. The DC cables leave the charger on both right and left sides. The cables and the connectors mounted on the cables are different for each charging standard and make them more or less flexible to reach out.

The figure below shows an example with the charger in the center with each type of connector and how far it can reach out. The green circle with continuous line describes the CHAdeMO cable 3.5m, the red circle with continuous line the CCS cable 3.5m. The broken lines describe the same type of cables with a length of 7m.



3.2 Different alignment possibilities

The charging inlets on a car can be located at different positions. The most common cars have their inlets located either on the front of the car, or on the left or right back side.


22-OCT-19 16/40

Charging inlet locations of important EVs




This makes some positions of the charger with respect to the parking space more favorable than others. Please keep this in mind when designing a site. Some possible situations are shown below:


Forward parking




Lateral Backward parking



Backward parking



Lateral Forward parking



22-OCT-19 17/40

4Site construction

4.1 About construction

The construction phase includes all work required to prepare the location and make it ready for the placement and connection of the Terra DC Wallbox charger. The construction phase can start when:

- The wall preparation work is done.
- All necessary permits are granted.
- The grid connection is available.

4.2 Power feed

The power cable enters the charger from below. Use foam or proper cable lugs and glands to prevent the entrance of animals from the AC or Ethernet cable inlet.

4.3 Instruction for a wall bearing

- 1. Drill and tap 4 holes and insert the plug for fixation in the wall at the indicated positions, refer to technical drawing in the Appendix A par. 10.1. For safety purpose the number of recommended fixing screws will be 4xST7.3x70, using an appropriate type of wall plugs (depending on wall's characteristics, structure and type). It is installer's responsibility to choose an appropriate wall plug, considering a load on each plug equal to 820 N.
- 2. Doing the four holes above, make sure that the free spaces for the cables of the Terra DC Wallbox are respected, refer to par. 2.2.1.

4.4 Power cable

- Cable type: two different cables
 - 3P+N+PE, shielded cables are optional if required by local law (Eu version and NAM 3-phase).
 - 2P+PE, shielded cables are optional if required by local law (NAM version 1-ph).
- Optional cable shielding must be attached to the PE Rail at both ends of the cable.
- The diameter of the cable conductor must be determined by your contractor / electrician.
- The maximum cross section surface of the cable conductor is 35 mm².
- The PE conductor of the power cable must have the same diameter as the phase conductors.

22-OCT-19 18/40

4.5 Internet connection

The preferred method of communication is to use the wireless 2G/3G modem that is integrated into the Charger. A customer SIM card is not required, a subscription for the SIM card is provided by ABB for selected countries.

If there is no wireless signal available, a standard wired internet connection is required. This connection must meet the following requirements:

• Ethernet, RJ45.

Cable type: 8P+PE, shielded.

• Recommendations:

For distances of 75 meters or less; HELUKAT 600E. Distances over 75 meters require a custom engineered solution.

• Recommended minimum bandwidth:

upload: 128 kb/s download: 4 Mb/s.

- Recommended availability: 99,9%.
- The connection must be available for the ABB service engineer and the NOC (Network Operation Center).
- Please contact ABB for a specific configuration.

In case the separate internet connection is not used, please assure the cable entry hole is closed, to assure the IP54 grade of the cabinet, and prevent insects and small animals to enter the cabinet.

22-OCT-19 19/40

5 Receiving, Placing and connecting

5.1 Receiving the Wallbox

The product is delivered by a transport company to a warehouse where it will be handed over.

Transporting the Terra DC Wallbox to its final location (last mile service) is not standard included in the order.




NOTICE

The delivery truck unloads the pallet carrying the Terra DC Wallbox.

The movement of the Terra DC Wallbox to its final location is the responsibility of the customer / contractor.

Check whether the Terra DC Wallbox has not been shaken or tilted.

• The cabinet is equipped with Shock Watch and Tilt Watch indicators.



Checking the Shock Watch and Tilt Watch PLUS sensors:

If the Shock Watch indicator is red, or the Tilt Watch PLUS indicator is tilted over 30°:


- 1. Do not refuse the delivery / receipt.
- 2. Make a notation on the delivery receipt and inspect cabinet for damage.
- 3. If damage is discovered, leave cabinet in original package and request immediate inspection from carrier within 3 days of delivery.
- 4. Contact your local ABB office.

22-OCT-19 20/40

5.2 Unpacking Wallbox, mounting preparations

5.2.1 Unpacking

The packaging of the Terra DC Wallbox can be removed without the use of tools and be careful because it could pollute of the environment.



- 1. Remove the plastic protection profiles.
- 2. Remove the Bottom Grid and the Lower Frontal Cover
- 3. Remove the Screws Package and make sure that contains:
 - Four hex bolts M8
 - Four screws M5
 - Two bolts M5
- 4. Remove the Wall Frame
- 5. Remove the Terra DC Wallbox.

22-OCT-19 21/40

6. For all components above, remove the outside and inner side shrink wrap.

5.2.2 Mounting preparations

Unpacking the IP BOX and verify that all the following items are present:

- M8x30 8.8 hex bolts (4x)
- M5 mounting screws (4x)
- M5 mounting bolts (2x)
- Wall frame
- Frontal cover
- Bottom grid cover

5.3 Move cabinet to position

5.3.1 Options

The only option to move the Terra DC Wallbox from the delivery truck to the location is through a forklift truck.



DANGER Hazardous voltage

Make sure the main switch of the power supply group for the product is set to the OFF position. Do a voltage check to make sure there is no electrical power on the cables or on the system and secure against resetting.



NOTICE Warranty

Damage due to moving the cabinet to its position is not considered a warranty issue.

5.4 Mounting the Terra DC Wallbox

Preconditions:

- Tools: Spanners size 17.
- Guide the power cable through the central cable gland and if required the Ethernet cable through the smaller gland.

22-OCT-19 22/40


5.4.1 Mounting the Terra DC Wallbox



NOTICE


The number of people that can lift a Terra DC Wallbox during installation is a minimum of two. In general, local regulations should be followed as the maximum weight to be lifted may vary country by country.

- 1. Carefully lower the Terra DC Wallbox onto its location.
- 2. Make sure not to entrap the cable(s).
- 3. Put the wall frame in the correct position on the wall bearing aligning the four holes of it with the correspondent ones on the wall bearing.
- 4. Tighten the four screws with stainless steel 8.8 hexagonal bolts.





5. Put the unit on the cabinet correctly aligning the 6 bolts (3 for each lateral side) between them.

22-OCT-19 23/40



6. Tighten the two M5 bolts on the lower side of the unit. Pay attention to the internal fan power supply cable.






7. Let the auxiliary power supply cable pass through the central gland and tight it.


22-OCT-19 24/40

8. <u>AFTER</u> the cable connection (refer to para 5.4.2 and 5.5), take the bottom grid and put it on the lower side of the unit and fix it by tightening two screws as shown in the following picture.






9. Take the lower frontal cover and put it on the lower side of the unit and fix it tightening two screws as showed in the following picture.



10. Center the holes on the plastic cover with the pins on the box (see picture)

22-OCT-19 25/40



11. Put the central cover on the unit and fix it tightening two screws located on the left and right side of the cover and (see detail on the following picture). Center the bottom pins and then rotate the cover and tight the 2 lateral screws.




5.4.2 Install cable gland(s)


The maximum diameter of the grid cable is 32 mm.

The minimum diameter of the grid cable is 22 mm with the standard fitted cable gland insert.


22-OCT-19 26/40



1. Slide the cable inside the grommets, ensure at least 10mm of cable external jacket inside the box (see notes at the end of this §, Before sliding the cable inside the grommet).



2. Push the cables back through the gland plate, until sufficient cable length is left to reach the cable terminals, make sure the PE cable is longer than the other cables.



3. Tighten the strain relief.




4. Slide the cable cover and screw the two screws

22-OCT-19 27/40

In case the separate internet connection is not used, please assure the cable entry hole is closed, to assure the IP54 grade of the cabinet, and prevent insects and small animals to enter the cabinet.

NOTE 1: a ferrite core is provided with the wallbox (plastic bag within the package) and needs to be installed in commissioning phase. The Ferrite needs to be inserted in the AC in cable and located in the screw cable cover (see picture below, left).

NOTE 2: a floating grounding cable is provided that is connected to the ground node. The mentioned cable has to be connected to the wall frame PEM in order to guarantee equal ground potential (see picture below, right).



5.5 Connect cables

5.5.1 Connect PE of power cable

Preconditions:

• Tools: Wire stripper pliers; wire-end lug pliers; wire-end lug.



DANGER Hazardous voltage

Make sure that the main switch of the power supply group for the product is set to the OFF position. Perform a voltage check and make sure that the electrical power is disconnected from the system.

1. Cut the PE wire of the power cable to the correct length (longer than other phases) to reach the PE connector.

22-OCT-19 28/40



NOTICE

For safety, it is recommended to make the PE wire longer than the phase wires. This makes sure that the PE wire stays connected as longest, if the Terra DC Wallbox is moved by a collision.

- 2. Use wire stripper pliers to remove 20 mm of the insulation from the end of the PE wire and attach the cable lugs.
- 3. Pull the cover a way from the connectors and remove them.
- 4. Loosen the bolts of the PE connector on the ground block
- 5. Attach the PE wire on to the PE block.
- 6. Tighten the bolts. The advised torque value is 2Nm.

5.5.2 Connect power cable

Preconditions:

• Tools: Wire stripper pliers; wire-end lug pliers; wire-end lugs.



DANGER


Hazardous voltage

Make sure that the main switch of the power supply group for the product is set to the OFF position. Perform a voltage check and make sure that the electrical power is disconnected from the system.

- 1. Cut the 3 phase and neutral wires of the power cable to the correct lengths to reach the connectors.
- 2. Use wire stripper pliers to remove 20 mm of the insulation from the ends of the wires and attach the cable ferrules.
- 3. Pull the covers a way from the connectors and remove them.
- 4. Loosen the bolts of the connectors.
- 5. Attach the four wires on to their connectors as indicated on the label on the relative terminal block (see the following picture as example).
 - From left to right (as showed in the following picture):
 - N terminal block blue
 - L3 terminal block grey
 - L2 terminal block grey
 - L1 terminal block grey

NOTE: if there is a NAM connection, only "L1" and "L2" terminal blocks are present.

22-OCT-19 29/40



- 6. Tighten the bolts. The advised torque value is 2.9Nm.
- 7. Connect the Fan connector to the mating one located on the lateral cable-gland

5.5.3 Connect network cable



WARNING

Leave the main switch switched off. The Terra DC Wallbox is not ready for use yet. Please contact the ABB Service department at least one week in advance to make an appointment for commissioning.



NOTICE

Only connect the network cable if a wireless 2G/3G connection is not possible.

Preconditions:

- Tools: Network cable pliers, RJ45 connector; network cable straight,
- 1.Cut the network cable to the correct length to reach the Ethernet connector. The connector is located near the bottom of the charger.
- 2.Use network cable pliers to install an RJ45 connector on to the network cable. Using the Ethernet color standard EIA/TIA T568A $\,$
- 3.Insert the RJ45 connector in to the Ethernet connector.

22-OCT-19 30/40

6 Commissioning

6.1 Commissioning preparation

Commissioning is the last phase necessary to get the Terra DC Wallbox operational. The purpose is to check the safe functioning of the charger for its operational purpose.

A certified service engineer from the ABB Service department or a trained engineer by ABB is required to perform the commissioning. During this commissioning, the safety and the functioning of the charger will be tested.

Before the service engineer can start, the following conditions must be met:

- All work described in Preparation, Construction and Placement and connection is done.
- Power is available.
- A local technician is present for assistance and to switch on the power.
- Internet access must be available in case 2/3G is not functional.
- A Combo compliant electric vehicle must be available for testing CCS charging.
- A CHAdeMO compliant electric vehicle must be available for testing the CHAdeMO charging.
- Any electric vehicle for instructing the site operator.



NOTICE

Warranty

It is not allowed to move the Terra DC Wallbox, after it is commissioned.

In case the Terra DC Wallbox is moved without approval from ABB, the warranty will be considered void. In case of relocation please contact the local ABB Service department.

Commissioning is executed according to the check list, this check list can be found in the Helios Suite Service tool that is available to the certified commissioning engineers or their supervising ABB organization. Also the following data is required for input:

- End-user Contact person (Create a contact if it doesn't exist).
- Charger address (Check the mentioned address, it will be the address the charger was shipped to).
- Coordinates longitude and latitude for plots on the maps. If there are more chargers on 1 location, make sure the coordinates are slightly different (at least 0,0001 degrees) to prevent being displayed on the same location.
- Site name if this is useful for better recognition (eg Shell petrol station Amsterdam).
- External fuse of the charger.

22-OCT-19 31/40

- SAT (Site Acceptance Test) date.
- Location remarks (any special remarks about the site, e.g. behind a gate, no photo cameras allowed etc.)
- Add a picture of the surrounding of the charger, upload the local CAF document A4 on the page of the charger in PDF
- Change Deliver status to <SAT>.

After completing the Site Acceptance Test, ABB's Network Operation Center will be triggered to perform a final check on the connection and configuration of the charger.

Upon approval the charger will be operational and initialized for use.

22-OCT-19 32/40

7 Cleaning of the cabinet

7.1 Cleaning of the cabinet

The Terra DC Wallbox Charger is powder coated. This coating must be kept in good condition.

Clean the Terra DC Wallbox Charger three times a year in the following way:

- Remove rough dirt by spraying with low-pressure tap water.
- Apply a neutral or weak alkaline cleaning solution and let it soak.
- Remove dirt by hand with a non-woven nylon hand pad.
- Rinse thoroughly with tap water.
- Do a check on the coating and on the front cover for damage.



NOTICE

When the Terra DC Wallbox Charger is exposed to rain, it is sufficient to clean it twice a year.



CAUTION

Do not apply high-pressure water jets. Water may leak into the Terra DC Wallbox Charger. If a high-pressure water jet has been used, make sure that the inside of the Terra DC Wallbox Charger is dry.

- Only use cleaning agents with a pH value between 6 and 8
- Do not use cleaning agents with abrasive components.
- Do not use abrasive tools.

22-OCT-19 33/40

8 Technical Data

8.1 Electrical data

Input		
Supply voltage	3 phase, 400 V AC: PE, N, L1, L2, L3 (EU)	
	1 phase / 2 phases, 208 V AC/240 V AC: PE, L1, L2 (NAM)	
	3 phase, 277Y/480Δ V AC: PE, N, L1, L2, L3 (NAM 3-ph)	
Input voltage range	400 V AC +10%, -15%(50 Hz)	
	208V AC/240 V AC +10%, -15% (60 Hz)	
	480 V AC +10%, -15% (60Hz)	
Maximum rated input current & power	3x40A (EU), 100A (NAM),24kVA	
Power factor	> 96%	
Efficiency	95% at nominal output power	
DC output (C)		
Maximum output power	22,5 kW (peak 24kW)	
Output voltage range	150-920 V DC (CCS 2)	
Maximum output current	60 A DC +/- 5% (CCS 2)	
DC output (J)		
Maximum output power	22,5 kW (peak 24kW)	
Output voltage range	150-500 V DC (CHAdeMO)	
Maximum output current	60 A DC (CHAdeMO)	

General	
DC connection standard	EN61851-23 / DIN 70121 CCS 2 CHAdeMO 1.0
DC cable length	3,5 or 7 meters +/- 10%
DC plug type	CCS 2 / JEVS G105 CHAdeMO
RFID data	

22-OCT-19 34/40

RFID system	FeliCa™1, NFC reader mode	
Network connection	GSM / CDMA modem	
	10/100 Base-T Ethernet	

22-OCT-19 35/40

8.2 Mechanical data

Mechanical data	
Dimensions (H x W x D)	770 mm x 585 mm x 300 mm
Weight	70 kg
Volume	0,135 m³
Dimensions including packaging (H X W x D)	650 mm x 1200 mm x 800 mm
Weight including packaging	80 kg
Mechanical impact protection	IK10

8.3 Environment

Environmental data		
Ingression protection	IP54	
Temperature range – Operation	-35°C to + 55°C	
	(derating applies between 45°C and 55°C)	
Temperature range - Storage	-40 °C to +70 °C	
Humidity	20% - 95% RH - non-condensing	
Operational noise level	55 dBA @25°C	
Altitude	2500 m max.	

8.4 Certifications

CE Certification

EMC: EN 61000-6-4 Class A emission; EN 61000-6-3 Class B emission (pending); EN 61000-6-2 immunity.

LVD: IEC 61851-23, IEC 61851-1, IEC 62196, IEC 60950, EN 61010, EN 60335 (see certificate)

RFID: ISO/IEC 14443 A/B, ISO/IEC15693, ISO 18902 NFC

22-OCT-19 36/40

9 Contact information



NOTICE

In case of problems

Please contact your local ABB Service organization or Service partner for first line problem analysis and solving. In case they cannot solve the problem, they will contact the second line Service organization.

ABB in your country

Please contact ABB in your country for sales, delivery and service information.

ABB EV Infrastructure global

ABB EV Infrastructure

Address Delftweg 65

2289 BA Rijswijk

The Netherlands


Telephone +31 70 307 62 00

Mail info.evi@nl.abb.com

22-OCT-19 37/40

10 Appendix A – Mounting points

10.1 Terra DC Wallbox Charger wall mounting



22-OCT-19 38/40

Appendix B - Disposal instruction 11

Directive on Waste Electrical and Electronic 11.1 Equipment (WEEE - 2012/19/EU)

ABB

ENGLISH

NEDERLASNDS

X

DEUTSCH

22-OCT-19 39/40



SLOVENČINA

MAGYAR



A leselejtezett elektromos és elektronikus berendezéseket az elektronické az elektronické zariadenia, ktoré sa zbie.

Laikantis Direktyvos (WEEE - 2012/19/EU) děl Elektriskás un elektroniskás leikártas ir jásavác
dezéseket az elektronos, és elektronikus berenrajú separovane v súlade so smemicou o odpade elektros ir elektroninés jrangos atlieku, elektros
dezéseke hulladkánní szádó (WEEE - 2012/19/EU)
elektronisko iskártu atkritumiem (WEEE - 2012/19/EU)
irányelv érlelmében külön kell grújlení
2012/19/EU)

2012/19/EU)

Z012/19/EU)

Z012/19/EU)



LIETUVIŲ



LATVIEŠU

Le describéen le le sambolum dereschem attivout lustina at jeuite lustrations in lustration pour le mêmet le la manura de journit product de pr



X

Αποιχητίων της χωριας σας.
Η μη ορθή διαχρίσματη πων αποβλήτων μπορά να έχει αρνηπικές επιπτώσεις στο περιβάλλον και στην ανθρώπητη υγεία λόγω της ενδεχόμενης ύπαρξης επιλόνουν αυτούν. Με τη αυτογρασία σας στη αυτογραφισιούρηση, ανακάλλοση και σέρισπόρη του προϊόντος και προστατείετε το περιβάλλον.

22-OCT-19 40/40